

KLARO GmbH  
Spitzwegstraße 63  
95447 Bayreuth  
Germany

Name: Martina Wermter  
Telephone: +49 241 75082-21  
Telefax: +49 241 75082-29  
E-Mail: m.wermter@pia-gmbh.com

Date: 2019-04-11

**Treatment efficiency vacation testing for Scandinavia of the small wastewater treatment plant KLARO Easy, attestation no. 350B22.A01**

To whom it may concern

We hereby confirm the ongoing evaluation of treatment efficiency of the small wastewater treatment plant **KLARO Easy** in a 4800 l tank for a vacation test on the testing field of PIA GmbH in Aachen, Germany.

The low occupation stress treatment efficiency testing of the small wastewater treatment plant **KLARO Easy** includes half a year with no inflow and nominal loading before and after the vacation phase. During nominal phase the plant is loaded with a hydraulic flow of 0.75 m<sup>3</sup>/d domestic wastewater. The system is currently being tested and was officially started with the nominal phase prior to the vacation phase on 18 March 2019. The testing is expected to be completed in November 2019.

Kind regards

PIA GmbH  
Prüfinstitut für Abwassertechnik  
Hergenrather Weg 30  
52074 Aachen  
GERMANY

Dipl.-Ing. Martina Wermter  
Head of department "European Testing – Wastewater Treatment"